



<b>AO.DESIGN</b>	<b>906 s kansas ave</b>
<b>785.271.7010</b>	<b>suite 200</b>
	<b>topeka, ks 66612</b>

## **ARCHITECT'S ADDENDUM TO THE CONTRACT DOCUMENTS**

ADDENDUM NO: One (bidder's questions)

DATE: Tuesday, April 26, 2024

PROJECT: 23-133 AIM CENTER OF EXCELLENCE AT SLN

OWNER: SALINA AIRPORT AUTHORITY  
2720 ARNOLD AVE  
SALINA, KANSAS

ARCHITECT: ARCHITECT ONE  
906 S KANSAS AVE, STE 200  
TOPEKA, KANSAS

Note: This Addendum No. 1, dated April 26, 2024 modifies/clarifies the above titled contract documents dated April 11, 2024. Where this Addendum modifies, changes, corrects or conflicts with the original Contract Documents, this Addendum shall govern. Where no modification, change, correction or conflict occurs, the original Contract Documents shall remain in force.

### **DESCRIPTION OF MODIFICATIONS TO THE CONTRACT DOCUMENTS:**

#### **Architectural**

1. Do the paint booths in the alternate have ceilings in them?
  - o No, they do not have ceilings. They will be open to the existing structure and building supported lighting above.
2. Are white melamine drawer boxes acceptable for this project?
  - o White melamine drawer boxes are called out on sheet number A-601.2. The sides and back are also acceptable to be melamine.

#### **Structural**

3. Sheet S500
  - o Disregard grating detail (11 – top); it is not used on the project. Note the disclaimers for multiple details indicating that they may not be specific to this particular project.
4. Can the AISC certification be waived if the fabricator includes third-party testing at their facility?
  - o Yes, a shop that is not AISC certified can be used as long as shop inspections by a third-party are performed.

END OF ADDENDUM 1 – NO ATTACHMENTS